

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0078:209 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** ADEMCO, 165 Eileen Way, Syosset, NY 11791  
Contact: Dave Kalmus (516) 921-6704

**DESIGN:** Model 5817CB Wireless Commercial and Household Fire Alarm Transmitter. The transmitter sends status, trouble and alarm information to the control unit via ultra-high frequency (UHF) 345 MHz. Unit is suitable for central station and local station protective signaling services. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC, 16.5 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation and UL label.

**APPROVAL:** Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

**NOTE:** Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.

02-04-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager